

DEMKO CERTIFICATE

Certificate No.	D-02331-A1
Page	1/3
Date of Issue	2017-10-16
Certificate Holder	SK TUOTE OY Kauppatie 9 Mustasaari, 65610 Finland
Manufacturer	SK TUOTE OY Kauppatie 9 Mustasaari, 65610 Finland
Production site	SK TUOTE OY Kauppatie 9 Mustasaari, 65610 Finland
Certified Product Model	Powered roof-ventilator VILPE ECO 110, VILPE ECO 190, VILPE ECO 220, VILPE ECO 250
Trademark	VILPE
Rated Voltage / Frequency	230V, 50Hz
Rated Current / Power	83W, 0.75A, 3200 r/min (VILPE ECO 110, VILPE ECO 190) 85W, 0,7A, 2580 r/min (VILPE ECO 220) 165W, 1.40A, 2560 r/min (VILPE ECO 250)
Insulation Class	I
Degree of protection (IP)	34
Tested acc. to	EN 60335-1:2012/A11:2014, EN 60335-1:2012, EN 60335-2-80:2003/A1:2004, EN 60335-2-80:2003/A2:2009, EN 60335-2-80:2003, EN 62233:2008
Test Report No.	NCS/FI 27884 M3 issued on 2017-09-13
Additional	See Page 2
Expire date	2018-08-21

Certification Manager
Jan-Erik Storgaard

This is to certify that representative sample(s) of the Product described herein ("Certified Product") have been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the D Mark Requirements. The Designated Certificate holder is entitled to use the d or for cables <DEMKO> for the Certified Product manufactured at the production site(s) identified above, in accordance with the D Mark Service Agreement, including without limitation the D Mark Testing and Certification Services Service Terms. Only those Products bearing the D Mark should be considered as being covered by UL's D Mark Service. This Certificate shall remain valid through the expiration date, unless terminated earlier in accordance with the Service Agreement including without limitation if the Standard identified on this Certificate is amended or withdrawn prior to the expiration date.

Certification Body

UL International Demko A/S, Borupvang 5A, DK-2750
Ballerup, Denmark, Tel. +45 44 85 65 65,
info.dk@ul.com
www.ul-europe.com



Appendix DEMKO CERTIFICATE

Certificate No. D-02331-A1
Page 2/3
Date of Issue 2017-10-16

External Certification Information:

NCS/FI 27884 M3 issued on 2017-09-13 by SGS Fimko Ltd

Additional Information:

The appliance is provided with a supply cord intended to be connected to a distribution box of the fixed installation. the appliance coupler on the supply cord is intended only use for service.

This replaces previous certificate D-02331-M2, due to addition of EN amendment A11:2014 and new connector.


Certification Body

UL International Demko A/S, Borupvang 5A, DK-2750
Ballerup, Denmark, Tel. +45 44 85 65 65, info.dk@ul.com
www.ul-europe.com



Appendix DEMKO CERTIFICATE

Certificate No. D-02331-A1
Page 3/3
Date of Issue 2017-10-16



Certification Body

UL International Demko A/S, Borupvang 5A, DK-2750
Ballerup, Denmark, Tel. +45 44 85 65 65, info.dk@ul.com
www.ul-europe.com

