




CERTIFICATE NCS/FI 29407 A1

Our Ref. 287077-1

Product	Powered roof-ventilator
Type	VILPE E80, VILPE E80 RT, VILPE E120, VILPE E150, VILPE E190, VILPE E220, VILPE E220XL
Trade mark	VILPE
Certificate Holder / Manufacturer	SK Tuote Oy Kauppatie 9 FI-65610 MUSTASAARI, FINLAND
Technical information	230V, 50Hz, 45...85W, 0,21...0,38A, Class I, IP34 (See page 2 for model detailed information)
Other information	-
The product is certified according to the following standard(s)	EN 60335-2-80:2003 + A1:2004 + A2:2009 EN 60335-1:2012 + A11:2014 EN 62233:2008
Validity	This certificate is valid until 05 January 2021 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.
Directive information	The product(s) fulfils the essential safety requirements for CE conformity marking according to the Low Voltage Directive (2006/95/EC) at the date of issue of the certificate.
Date of issue	07 March 2017
Signature	SGS Fimko Ltd  Markus Ahvenus Certification Manager

This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Manufacturing site(s)

SK Tuote Oy
Kauppatie 9
FI-65610 MUSTASAARI, FINLAND

Additional information



VILPE E80 RT 230V, 50Hz, 46W, 0,22A, 2100min-1, IP34
 VILPE E80: 230V, 50Hz, 45W, 0,21A, 1900min-1, IP34
 VILPE E120: 230V, 50Hz, 52W, 0,23A, 2350min-1, IP34
 VILPE E150: 230V, 50Hz, 45W, 0,21A, 1900min-1, IP34
 VILPE E190: 230V, 50Hz, 52W, 0,23A, 2350min-1, IP34
 VILPE E220: 230V, 50Hz, 85W, 0,38A, 2600min-1, IP34
 VILPE E220XL: 230V, 50Hz, 85W, 0,38A, 2600min-1, IP34

Copy of the certificate, this Notification and other agreed documentation are transferred directly from SGS Fimko to DEMKO, NEMKO and SEMKO.

This certificate replaces previous NCS/FI certificate NCS/FI 29407, dated 05 January 2016. The certificate has been updated due to addition of alternative capacitor and new capacitor housing.

Is based on test / Our ref.

278827-1
278827-1 Amendment 1



Supplement to Certificate: **NCS/FI 29407 A1**

Our ref.
278827

07 March 2017

NORDIC CERTIFICATION SERVICE

We hereby confirm that the product(s) appearing from the certificate with above certificate reference also comply(ies) with requirements for secondary certification in the following countries: Denmark, Norway, Sweden

NOTIFICATION

Certificate holder for Denmark, Norway and Sweden	SK Tuote Oy Kauppatie 9 FI-65610 MUSTASAARI, FINLAND
	Please send the invoice and the certificate directly to: SK Tuote Oy, Attn. Veli-Pekka Lahti (email: veli-pekka.lahti@sktuote.fi)
Safety standard(s) applied	EN 60335-2-80:2003 + A1:2004 + A2:2009 EN 60335-1:2012 + A11:2014 EN 62233:2008
Deviations	Not applicable
EMC requirements	-
The assignment is based on	Testing in own premises of SGS Fimko.
Limitations or reservations regarding the testing / examination performed	None
Certification marks	Affixing of the certification mark(s) of the Nordic body(ies) on the product must not take place before notice about national certification is received from the individual body.
Production surveillance	Will be carried out by SGS Fimko according to agreed procedures.
Other information	Copy of the certificate, this Notification and other agreed documentation are transferred directly from SGS Fimko to DEMKO, NEMKO and SEMKO. This certificate replaces previous NCS/FI certificate NCS/FI 29407, dated 05 January 2016. The certificate has been updated due to addition of alternative capacitor and new capacitor housing.
Test samples must be submitted to the secondary body(ies)	No
Date of issue	07 March 2017

This Notification may be challenged if it is more than 3 years old.

SGS Fimko Ltd

Signature



Markus Ahvenus
Certification Manager

This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Fimko Ltd.

Särkiniementie 3 P.O. Box 30 FI-00211 Helsinki, Finland
t. +358 9 696 361 f. +358 9 692 5474 www.sgs.fi

Business ID 0978538-5 Member of the SGS Group (SGS SA)