


CERTIFICATE NCS/FI 27884 M2



Our Ref. 276250-1

Product	Powered roof-ventilator
Type	VILPE ECO 110, VILPE ECO 190, VILPE ECO 220, VILPE ECO 250
Trade mark	VILPE
Certificate Holder / Manufacturer	SK Tuote Oy Kauppatie 9 FI-65610 MUSTASAARI FINLAND
Technical information	230V, 50Hz, Class I, IP34 83W, 0.75A, 3200 r/min (VILPE ECO 110, VILPE ECO190) 85W, 0.7A, 2580 r/min (VILPE ECO 220) 165W, 1.40A, 2560 r/min (VILPE ECO 250)
Other information	-
The product is certified according to the following standard(s)	EN 60335-2-80:2003 + A1:2004 + A2:2009 EN 60335-1:2012 EN 62233:2008
Validity	This certificate is valid until 21 August 2018 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.
Directive information	The product(s) fulfils the essential safety requirements for CE conformity marking according to the Low Voltage Directive (2006/95/EC) at the date of issue of the certificate.
Date of issue	16 May 2014
Signature	SGS Fimko Ltd  Kurt Söderblom Certification Manager



This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Appendix to Certificate: 27884 M2

Manufacturing site(s) SK Tuote Oy
Kauppatie 9
FI-65610 MUSTASAARI
FINLAND

Additional information The appliance is provided with a supply cord intended to be connected to a distribution box of the fixed installation. The appliance coupler on the supply cord is intended only use for service.

This certificate replaces previous certificate NCS/FI 27884 M1, dated 21 August 2013. The certificate has been updated due to the addition of model VILPE ECO 250.

Is based on test / Our ref. 268476-1
268476-1 Amendment-1
268476-1 Amendment-2

Supplement to Certificate: NCS/FI 27884 M2

Our ref.
276250-1

16 May 2014

NORDIC CERTIFICATION SERVICE

We hereby confirm that the product(s) appearing from the certificate with above certificate reference also comply(ies) with requirements for secondary certification in the following countries: Denmark, Norway, Sweden

NOTIFICATION

Certificate holder for Denmark, Norway and Sweden	SK Tuote Oy Kauppatie 9 FI-65610 MUSTASAARI FINLAND
	Please send the invoice and the certificate directly to the certificate holder. Attn: Veli-Pekka Lahti, veli-pekka.lahti@sktuote.fi
Safety standard(s) applied	EN 60335-2-80:2003 + A1:2004 + A2:2009 EN 60335-1:2012 EN 62233:2008
Deviations	Not applicable
EMC requirements	-
The assignment is based on	Testing in own premises SGS Fimko Ltd.
Limitations or reservations regarding the testing / examination performed	None
Certification marks	Affixing of the certification mark(s) of the Nordic body(ies) on the product must not take place before notice about national certification is received from the individual body.
Production surveillance	Will be carried out by SGS Fimko according to agreed procedures.
Other information	Copy of the certificate, this Notification and other agreed documentation are transferred directly from SGS Fimko to DEMKO, NEMKO and SEMKO.
Test samples must be submitted to the secondary body(ies)	No
Date of issue	16 May 2014

This Notification may be challenged if it is more than 3 years old.

SGS Fimko Ltd

Signature



Kurt Söderblom
Certification Manager