

CERTIFICATE FI/42140/A1

Our Ref. HEL-CERT240200234-05



Product Powered roof ventilator
Type ECo110 FLOW, ECo125 FLOW, ECo160 FLOW, ECo160 FLOW XL, ECo200 FLOW
Trademark VILPE
Certificate Holder VILPE Oy
Kaupatie 9, FI-65610, Mustasaari, Finland

Technical information
ECo110 FLOW: 230V, 50Hz, 0,75A, 83W, IP54, Class I, 3200 r/min;
ECo125 FLOW: 230V, 50Hz, 0,75 / 0,7 / 0,9 A, 83 / 87 / 90 W, IP54, Class I, 3200 / 3300 / 3240 r/min;
ECo160 FLOW: 230V, 50Hz, 0,7A, 85W, IP54, Class I, 2580 r/min
ECo160 FLOW XL: 230V, 50Hz, 0,7A, 85W, IP54, Class I, 2580 r/min;
ECo200 FLOW: 230V, 50Hz, 1,40A, 170W, IP54, Class I, 2510 r/min

Other information -

The product is certified according to the following standard(s)
EN 60335-1:2012 + A11:2014 + A13:2017 + A1:2019 + A2:2019 + A14:2019 + A15:2021 + A16:2023
EN 60335-2-80:2003 + A1:2004 + A2:2009

Validity This certificate is valid until 2029-10-11 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Date of issue 2024-10-25

SGS Fimko Ltd

Signature


Peter Fagerstedt
Certification Manager



Manufacturer	VILPE Oy Kauppatie 9, FI-65610, Mustasaari, Finland
Manufacturing site	VILPE Oy Kauppatie 9, FI-65610, Mustasaari, Finland
Directive information	The certified product(s) fulfils requirements of mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.
Additional information	This certificate replaces the previous certificate FI/42140, dated 2024-10-11, due to update in technical details.
As shown in the Test Report(s) No(s):	HELES2409000808-1