



Reference No. SE-S-2002617

Powered roof ventilator

i owered roof ventuator				
Type designation:	ECo200 FLOW			
Certificate holder:	VILPE Oy Kauppatie 9 65610 Mustasaari FINLAND			
The product complies with the standard(s):	EN 60335-1:2012+A11+A13+A1+A14+A2 EN 60335-2-80:2003+A1+A2 EN 62233:2008			
Date of expiry:	26 March, 2025			
EU Directive information:	According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.			
Additional information in Append	tertek			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Place: Kista - Stockholm

Date: 16 November, 2020

Intertek Semko AB, Product Certification

Leif Mattsson

Certification Body:

Signed:

Intertek Semko AB Page 1 of 2



APPENDIX:

Reference No. SE-S-2002617

Tec	hni	cal D	ata:
100		cai D	atu.

Type designation ECo200 FLOW

 Rated voltage (V)
 230V

 Rated current (A)
 1.40A

 Rated power (W)
 170W

 Frequency (Hz)
 50Hz

 Class
 I

 IP-Class
 54

 Trademark
 VILPE

Test Report 297613-1, 297613-1 Amendment 1, 297613-1 Amendment 2

Manufacturing Sites: VILPE Oy

Kauppatie 9

656 10 MUSTASAARI

FINLAND

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

The instruction for use shall be written in a language acceptable according to the national regulation in the country where the product is to be used.

This certificate is based on a certificate with ref. No. FI/40625/A2 dated 03 November 2020, issued by SGS Fimko Ltd according to the Nordic Certification Service Agreement.

This certificate replaces previously issued ref. No. SE-S-2001695 dated 11 June 2020. A new certificate has been issued on account of addition of alternative switch.

Certification Body: Intertek Semko AB, Product Certification Place: Kista - Stockholm

Signed: Date: 16 November, 2020

Leif Mattsson

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement, Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Semko AB Page 2 of 2