



Reference No. SE-S-2002636R2

## Powered roof ventilator

**Type designation:** ECo110 FLOW, ECo125 FLOW, ECo160 FLOW,

ECo160 FLOW XL, ECo200 FLOW

**Certificate holder:** VILPE Oy

Kauppatie 9, FI-65610, Mustasaari, Finland

The product complies with

the standard(s):

EN 60335-1:2012+A11+A13+A1+A14+A2+A15+A16

EN 60335-2-80:2003+A1+A2

**Date of expiry:** 25 October, 2029

**EU Directive information:** The product listed has been evaluated by a Third Party Body and deemed

to meet the listed standard(s). This Certificate can be used in support of a claim in meeting relevant EU legislation and mandatory Conformity Marking. And in accordance with EU law, the claim is the sole obligation of

the Manufacturer/Importer.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification Place: Kista - Stockholm

Signed: Date: 30 October, 2024

Anneli Averland Johansson

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This certificate is not issued under accreditation, by a non-approved body.

Intertek Semko AB Page 1 of 2 CIL



## **APPENDIX:**

Reference No. SE-S-2002636R2

**Technical Data:** 

*Type designation* ECo110 FLOW, ECo125 FLOW, ECo160 FLOW,

ECo160 FLOW XL, ECo200 FLOW

Rated voltage (V) ECo110 FLOW: 230V, 50Hz, 0,75A, 83W, IP54, Class I, 3200 r/min;

ECo125 FLOW: 230V, 50Hz, 0,75 / 0,7 / 0,9 A, 83 / 87 / 90 W, IP54, Class I,

3200 / 3300 / 3240 r/min;

ECo160 FLOW: 230V, 50Hz, 0,7A, 85W, IP54, Class I, 2580 r/min ECo160 FLOW XL: 230V, 50Hz, 0,7A, 85W, IP54, Class I, 2580 r/min; ECo200 FLOW: 230V, 50Hz, 1,40A, 170W, IP54, Class I, 2510 r/min

Trademark VILPE

Test Report HELES2409000808-1

Product information

**Manufacturing Sites:** VILPE Oy

Kauppatie 9, FI-65610, Mustasaari, Finland

The instruction for use shall be written in a language acceptable according to the national regulation in the country where the product is to be used.

This certificate is based on a certificate with ref. No. FI/42140/A1 dated 25 October 2024, issued by SGS Fimko Ltd according to the Nordic Certification Service Agreement.

This certificate replaces previously issued ref. No. SE-S-2002636R1 dated 24 August 2022. A new certificate has been issued due to addition of new models and update of standard EN 60335-1.

Certification Body: Intertek Semko AB, Product Certification Place: Kista - Stockholm

Signed: Date: 30 October, 2024

Anneli Averland Johansson

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement, Intertek assumes no liability to any party, other than to the Client is accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This certificate is not issued under accreditation, by a non-approved body.

Intertek Semko AB Page 2 of 2 CIL