

CERTIFICATE FI/42614 Issue 1

Our Ref. HEL-CERT240200234-07



Product Powered roof ventilator

Type ECo110 FLOW, ECo125 FLOW, ECo160 FLOW, ECo160 FLOW XL, ECo200 FLOW, EC110 FLOW, EC125 FLOW, EC160 FLOW, EC160 FLOW XL, EC200 FLOW

Trademark VILPE

Certificate Holder VILPE Oy
Kauppatie 9, FI-65610, Mustasaari, Finland

Technical information

ECo110 FLOW: 230V, 50Hz, 0,75A, 83W, IP54, Class I, 3200 r/min;
ECo125 FLOW: 230V, 50Hz, 0,75 / 0,7 / 0,9 A, 83 / 87 / 90 W, IP54, Class I, 3200 / 3300 / 3240 r/min
ECo160 FLOW, ECo160 FLOW XL: 230V, 50Hz, 0,7A, 85W, IP54, Class I, 2580 r/min;
ECo200 FLOW: 230V, 50Hz, 1,40A, 170W, IP54, Class I, 2510 r/min
EC110 FLOW: 230V, 50Hz, 0,75A, 83W, IP54, Class I, 3200 r/min
EC125 FLOW: 230V, 50Hz, 0,75 / 0,7 / 0,9 A, 83 / 87 / 90 W, IP54, Class I, 3200 / 3300 / 3240 r/min
EC160 FLOW, EC160 FLOW XL: 230V, 50Hz, 0,70A, 85W, IP54, Class I, 2580r/min
EC200 FLOW: 230V, 50Hz, 1,40A, 170W, IP54, Class I, 2510r/min

Other information -

The product is certified according to the following standard(s)

EN 60335-1:2012 + A11:2014 + A13:2017 + A1:2019 + A2:2019 + A14:2019 + A15:2021 + A16:2023
EN 60335-2-80:2003 + A1:2004 + A2:2009

Validity This certificate is valid until 2029-10-11 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Date of issue 2026-05-20

SGS Fimko Oy

Signature


Peter Fagerstedt
Certification Manager



Manufacturer VILPE Oy
Kauppatie 9, FI-65610, Mustasaari, Finland

Manufacturing site VILPE Oy
Kauppatie 9, FI-65610, Mustasaari, Finland

Additional information This certificate replaces the previous certificates FI/42140/A1, dated 2024-10-25, due to addition of new alternative motors and new model names

As shown in the Test Report(s) No(s): HELES2409000808-1, HELES2409000808-1 Amendment 1